

**Contractor Questions**  
**For**  
**Solicitation No. SCO150-16-R-0003**  
**Metallic Roof Cover Construction for CNP Bus – Santa Marta, Colombia**

Following is a list of the questions that were submitted by prospective offerors for the above solicitation. Each question is followed by the Government's response.

**Question #1:** What are the dimensions of the plate subfloor? There is no indication either in the specification or drawings?

**Answer:** *The dimension of the concrete slab are shown in drawing S-1 which covers the complete area to be demolished and replaced for the roof cover foundation which is approximately 15 m x 5 m. Drawing S-1 also shows the thickness of this concrete slab.*

**Question #2:** In Annex 3 indicates that the chain link mesh must be hollow mesh 2" and the specifications of the 3.02 item indicates that it should be 1 ½". Please clarify this?

**Answer:** *As indicated on the technical specifications, the fence shall be supplied and installed in 1½" x 1 ½" hollow caliber 10 chain link.*

**Question #3:** What should be the gauge of the pipe galvanized of 2" of the enclosure? In the PDF planes, this is not appreciated.

**Answer:** *The galvanized pipe shall be gauge 10.*

**Question #4:** In the drawings is indicated that the enclosure poles are each 3.25. Is it necessary to place an additional pole at the midpoint?

**Answer:** *The contractor shall include a galvanized pole at the middle of the distance for the chain link fence between the metallic columns or a diagonal pole in order to guarantee the fence stiffness.*

**Question #5:** Please confirm whether the existing plate should be demolished to make the excavation and fill or only to demolish the area of the footings and beams.

**Answer:** *The area that shall be demolished (as mentioned in Q#1) is the complete area where the concrete slab, footing and beams will be build.*

**Question #6:** At what level regarding the existing land should be left the new plate?

**Answer:** *As shown during the Pre-proposal meeting the level of the new concrete slab is the same as the existing concrete slab next to it.*

**Question #7:** In the PDF drawings all the details cannot be seen. It is possible to get AutoCAD drawings?

**Answer:** *The contractors that require the AutoCAD drawings shall send an e-mail to [moralesil@state.gov](mailto:moralesil@state.gov) requesting these drawings.*

**Question #8:** In the plane S 2/2 refers to roofing Sandwich type e = 3 cm and specifications in item 3.03 only refers to thermo acoustic tile. Please clarify this?

**Answer:** *The contractor shall consider thermos acoustic tile sandwich type for the roof cover.*

**Question #9:** As per SF1442, block 13 A. “Sealed offers in original and 2 copies to perform the work required are due at the place specified in item 8 by 2:00 PM local time December 10, 2015”. Please, clarify if the three volumes (Volumes I, II and III) the offer consists of shall be packaged separately or not both in the original offer and in the 2 requested copies?

**Answer:** *The three volumes shall be delivered separately, and for the three volumes an original and 1 copy are required.*